

**Klippon BDX (compensating elements)  
KLIPPON BDX M20 B**

**Weidmüller Interface GmbH & Co. KG**  
Klingenbergstraße 26  
D-32758 Detmold  
Germany  
Fon: +49 5231 14-0  
Fax: +49 5231 14-292083  
[www.weidmueller.com](http://www.weidmueller.com)



Pressure-compensation elements ensure good ventilation of the enclosure and prevent the build-up of condensation while maintaining the appropriate IP class of protection.

**General ordering data**

|            |                                                                                           |
|------------|-------------------------------------------------------------------------------------------|
| Type       | KLIPPON BDX M20 B                                                                         |
| Order No.  | <a href="#">2519520000</a>                                                                |
| Version    | Klippon BDX (compensating elements),<br>Compensating element, M 20, 10 mm, IP66,<br>Brass |
| GTIN (EAN) | 4050118532029                                                                             |
| Qty.       | 1 pc(s).                                                                                  |

## Klippon BDX (compensating elements) KLIPPON BDX M20 B

**Weidmüller Interface GmbH & Co. KG**  
Klingenbergstraße 26  
D-32758 Detmold  
Germany  
Fon: +49 5231 14-0  
Fax: +49 5231 14-292083  
www.weidmueller.com

## Technical data

### Dimensions and weights

|            |       |                 |            |
|------------|-------|-----------------|------------|
| Length     | 22 mm | Length (inches) | 0.866 inch |
| Width      | 27    | Width (inches)  | 1.063 inch |
| Net weight | 62 g  |                 |            |

### Environmental Product Compliance

REACH SVHC Lead 7439-92-1

### Certificate numbers cable gland

|                                        |                    |                                         |                      |
|----------------------------------------|--------------------|-----------------------------------------|----------------------|
| Approval conditions                    | ATEX, IECEx, EAC   | Certificate no. cable gland (ATEX)      | SIRA 09ATEX3321X     |
| Certificate no. cable gland (CSA)      | 2310046            | Certificate no. cable gland (EAC)       | RU C-GB.ГБ06.B.00098 |
| Certificate no. cable gland (IECEx)    | IECEx SIR 09.0132X | Certificate no. cable gland (LLOYDSREG) | 10/00056             |
| Certificate no. cable gland (MARITREG) | 09.00783.011       |                                         |                      |

### General information

|                                     |                                     |                                     |                                        |
|-------------------------------------|-------------------------------------|-------------------------------------|----------------------------------------|
| Material                            | Brass                               | External thread                     | M 20                                   |
| Pitch of thread                     | 1.5 mm                              | Length of thread                    | 10 mm                                  |
| AF size 1                           | 27 mm                               | Impact resistance                   | 7 J ATEX version                       |
| Protection degree                   | IP66                                | Protection degree with GWDR         | IP66                                   |
| Operating temperature range, min.   | -60 °C                              | Operating temperature range, max.   | 200 °C                                 |
| Head diameter                       | 26.2 mm                             | Air flow                            | 0.25 l / 1 h                           |
| Filter                              | Bronze insert (90% copper, 10% tin) | O-Ring                              | Silicone                               |
| Sealing                             | Silicone                            | Tightening torque                   | 10 Nm                                  |
| Torque for connecting adapter, min. | 10 Nm                               | Torque for connecting adapter, max. | 10 Nm                                  |
| Torque for lock nut, min.           | 10 Nm                               | Torque for lock nut, max.           | 10 Nm                                  |
| Explosion protection type           | Improved safety Ex e                | Standards                           | IEC 60079-0, IEC 60079-7, IEC 60079-31 |

Note: protection class

- The venting element should be fitted on the bottom side of the enclosure, aligned vertically with the thread upwards, and at the lowest point to permit proper drainage. - The supplied assembly instructions must be read prior to installation and strictly adhered to. - The water flow rate was tested using a water-filled, empty enclosure (no pressure or heat-producing internal components). The water flow rate may vary due to operational parameters and environmental conditions.

### Classifications

|             |             |            |             |
|-------------|-------------|------------|-------------|
| ETIM 6.0    | EC000814    | ETIM 7.0   | EC000814    |
| eClass 9.0  | 27-14-44-25 | eClass 9.1 | 27-14-44-90 |
| eClass 10.0 | 27-14-44-25 |            |             |

### Klippon BDX (compensating elements) KLIPPON BDX M20 B

**Weidmüller Interface GmbH & Co. KG**  
Klingenbergstraße 26  
D-32758 Detmold  
Germany  
Fon: +49 5231 14-0  
Fax: +49 5231 14-292083  
[www.weidmueller.com](http://www.weidmueller.com)

## Technical data

### Approvals

Approvals



ROHS

Conform

### Downloads

Engineering Data

[EPLAN](#)

Engineering Data

[STEP](#)